

180 KVA 3 PHASE 50Hz

GENERATING SET MODEL JP-180 Output Ratings Prime Standby 380-415 V, 3 ph, 50 Hz, 1500 rpm 180 KVA 200 KVA 144 KW 160 KW 380-415 V, 3 ph, 60 Hz, 1800 rpm 200 KVA 219 KVA

160 KW

ENGINE/ TECHNICAL DATA

Compression Ratio

Frequency and Engine Speed

Ratings at 0.8 Power Factor **Engine Make Perkins** 1106A-70TAG3 **Engine Model** Electronic **Governing Type** 6 **Number of Cylinders Cylinder Arrangement** Vertical in line Bore and Stroke mm 105 X 127 **Displacement/ Cubic Capacity litres** 6.6 Turbocharged, air to air charge cooled Induction System 4 stroke Cycle **Direct Injection Combustion System**

Gross Engine Power kW(hp)		
Fuel Consumption @50% load L/hr	20.5	25.5
@75% load L/hr	31.0	36.8
@100% load L/hr	40.2	41.3
Total Lubrication System Capacity litres	16.5	16.5
Total Coolant Capacity (inc. radiator) litres	21	21
Exhaust Temperature: °C	580	580

Image is for Illustrative purpose only





16:1

60Hz & 1800rpm

50Hz & 1500rpm

60Hz

175 KW

200 KVA

3 PHASE

ALTERNATOR DATA

Make	UPS/ Leroy Somer
Model	UPS274G/LSA (TAL) 46A
No. of Bearings	1
Insulation class	Н
Wires	6/12
Ingress Protectio	n IP23
Excitation Systen	n Shunt
Winding Pitch	2/3

Overspeed	2250 mn ⁻¹
Voltage Regulation (steady)	±1%

CONTROL PANEL

Make	DeepSea
Model	4000 Series

The **DSE 4000** *series* is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm Indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L-L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- Hours run counter
- Battery volts
 - Fail to start/stop
- Emergency stop
- Failed to reach loading voltage/frequency
- Charge fail
- Low DC Voltage
 - CAN diagnostics and CAN fail/error

: +971 6 741 0802, M +971 5 2641 4219

PO BOX: 3794, Ajman, UAE

E-mail: info@jimenpower.com Web: www.jimenpower.com

STANDARD SPECIFICATIONS

180 KVA

3 PHASE 50Hz

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine

2. ENGINE FILTRATION SYSTEM

- · Cartridge type dry air filter.
- Two cartridge type fuel filter.
- Full flow lube oil filter. All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

4. EXHAUST SYSTEM

Exhaust gas flow Maximum allowable back pressure 31..3 (m3/min) 18.0 (kPa)

5. CIRCUIT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx.. 8 hours running at Full load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and the drain plug

7. ALTERNATOR

7.1 INSULATION SYSTEM

- . The insulation system is Class H.
- All windings are impregnated in either a triple dip thermoset-Ting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special
- Heavy coat of antitracking varnish additional protection Against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains

The Voltage Regulation at ±1%. Nominal adjustment by means of a trim pot incorporated on the AVR.

8. MOUNTING ARRANGEMENT

8.1 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between Engine/Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.3 SAFETY GUARDS

The Fan & Fan Drive along with the battery Charging Alternator are Safety Guard protected for personnel

200 KVA

3 PHASE

9. FACTORY TEST

60Hz

- The Generating set is load tested before dispatch
- · All protective devise control functions and site load conditions are simulated. The generator and its systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and

11. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning/ Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards, BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.


13. WARRANTY


All of the Generating sets are covered under a warranty policy For a period of 12 months or 1000 working hours. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries.)

In line with the continuous product development, we reserve The right to change specifications without notice.


STANDARD GENERATOR DIMENSION AND WEIGHT

Silent Type (with Soundproof Canopy)











Open Type (without Soundproof Canopy)





PO BOX: 3794, Ajman, UAE E-mail: info@jimenpower.com Web: www.jimenpower.com

Tel : +971 6 741 0802, M +971 5 2641 4219 Fax : +971 6 740 8056