

45 KVA 3 PHASE 50Hz

GENERATING SET MODEL JP-45 Prime Standby 380-415 V, 3 ph, 50 Hz, 1500 rpm 45 KVA 50 KVA 36 KW 40 KW 380-415 V, 3 ph, 60 Hz, 1800 rpm 53.1 KVA 58 KVA 42.5 KW 46.4 KW

ENGINE/ TECHNICAL DATA			
		Ratings at 0.8 Power Factor	
Engine Make		Perkins	
Engine Model		1103A-33TG1	I
Governing Type		Mechanical	
Number of Cylinders		3	
Cylinder Arrangement	١	Vertical in line	

Bore and Stroke mm	105 X 127
Displacement/ Cubic Capacity litres	3.3
Induction System	Naturally Aspirated
Cycle	4 stroke
Combustion System	Direct Injection
Compression Ratio	2
Frequency and Engine Speed	50Hz & 1500rpm 60Hz & 1800rpm

Gross Engine Power kW(hp)		
Fuel Consumption @50% load L/hr	5.8	
@75% load L/hr	8.2	
@100% load L/hr	10.8	12.0
Total Lubrication System Capacity litres	8.5	8.5
Total Coolant Capacity (inc. radiator) litres	10.2	10.2
Exhaust Temperature: °C	537	537

Image is for Illustrative purpose only



Tel

Fax



60Hz

53 KVA

3 PHASE

ALTERNATOR DATA

Make	UPS/ Leroy Somer
Model	UPS224C/LSA (TAL) 42E
No. of Bearings	1
Insulation class	Н
Wires	6/12
Ingress Protection	n IP23
Excitation System	n Shunt
Winding Pitch	2/3

Overs	peed	2250 mn ⁻¹
34 44		 101

Voltage Regulation (steady) ±1%

CONTROL PANEL

Make	DeepSea
Model	4000 Series

The **DSE 4000** *series* is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm Indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L-L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
 - Hours run counter
- Battery volts
 - Fail to start/stop
 - Emergency stop
- Failed to reach loading voltage/frequency
- Charge fail
- Low DC Voltage
 - CAN diagnostics and CAN fail/error

: +971 6 741 0802, M +971 5 2641 4219

PO BOX: 3794, Ajman, UAE

E-mail: info@jimenpower.com Web: www.jimenpower.com

STANDARD SPECIFICATIONS

45 KVA

3 PHASE

50Hz

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

- · Cartridge type dry air filter.
- Two cartridge type fuel filter.
- Full flow lube oil filter.
 All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

4. EXHAUST SYSTEM

Exhaust gas flow Maximum allowable back pressure 31..3 (m3/min) 18.0 (kPa)

5. CIRCUIT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx.. 8 hours running at Full load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and the drain plug.

7. ALTERNATOR

7.1 INSULATION SYSTEM

- . The insulation system is Class H.
- All windings are impregnated in either a triple dip thermoset-Ting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin
- Heavy coat of antitracking varnish additional protection Against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains

The Voltage Regulation at ±1%. Nominal adjustment by means of a trim pot incorporated on the AVR.

8. MOUNTING ARRANGEMENT

8.1 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between tge Engine/Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.3 SAFETY GUARDS

The Fan & Fan Drive along with the battery Charging Alternator are Safety Guard protected for personnel protection.

60Hz

53 KVA

3 PHASE

9. FACTORY TEST

- The Generating set is load tested before dispatch
- All protective devise control functions and site load conditions are simulated. The generator and its systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning/ Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards, BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.

13. WARRANTY

All of the Generating sets are covered under a warranty policy For a period of 12 months or 1000 working hours. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries.)


In line with the continuous product development, we reserve The right to change specifications without notice.


1180.00


320.00

STANDARD GENERATOR DIMENSION AND WEIGHT


Silent Type (with Soundproof Canopy)








Open Type (without Soundproof Canopy)





-750.00-

Tel : +971 6 741 0802, M +971 5 2641 4219 Fax : +971 6 740 8056 PO BOX: 3794, Ajman, UAE

E-mail: info@jimenpower.com Web: www.jimenpower.com