

80 KVA 3 PHASE 50Hz

GENERATING SET MODEL JP-80 Output Ratings Prime Standby 380-415 V, 3 ph, 50 Hz, 1500 rpm 80 KVA 88 KVA 64 KW 70 KW 380-415 V, 3 ph, 60 Hz, 1800 rpm 92 KVA 102 KVA 73.8 KW 81.7 KW

FNGINE	TECHN	ICAL	DATA

		Ratin	gs at 0.8 Power Factor
Engine Make		Perkins	
Engine Model	1104A-44TG2		
Governing Type		Mechanical	
Number of Cylinders		4	
Cylinder Arrangement		Vertical in line	
Bore and Stroke mm		105 X 127	
Displacement/ Cubic Capacity litres		4.4	
Induction System		Turbocharged	
Cycle		4 stroke	
Combustion System	Direct Injection		
Compression Ratio		17.25:1	
Frequency and Engine Speed	50Hz	& 1500rpm 6	0Hz & 1800rpm

Frequency and Engine Speed	50Hz & 1500rpm	60HZ & 1800rpm
1		
Gross Engine Power kW(hp)	73.4(98.4)	80.7(108.2)
Fuel Consumption @50% load L/hr	11.3	13.5
@75% load L/hr	16.9	18.7
@100% load L/hr	20.6	23.7
Total Lubrication System Capacity litres	8	8
Total Coolant Capacity (inc. radiator) litres	13.0	13.0
Exhaust Temperature: °C	580	580

Image is for Illustrative purpose only





60Hz

92 KVA

3 PHASE

ALTERNATOR DATA

Make	UPS/ Leroy Somer	
Model	UPS224G/LSA (TAL) 44B	
No. of Bearings	1	
Insulation class	Н	
Wires	6/12	
Ingress Protection	n IP23	
Excitation System	n Shunt	
Winding Pitch	2/3	

Overspeed	2250 mn ⁻¹	
Voltage Regulation (steady)	±1%	

CONTROL PANEL

	Make	DeepSea
I	Model	4000 Series

The **DSE 4000** *series* is an Auto Start Control Module for single genset applications. It includes a backlit LCD display which clearly shows the status of the engine all the times. This module can either be programmed using the front panel or by using the DSE configuration suite PC software.

Metering and Alarm Indications:

- Generator frequency
- Underspeed, Overspeed
- Generator volts (L-L-L-N)
- Generator current
- Engine oil pressure
- Engine coolant temperature
- Hours run counter
- Battery volts
 - Fail to start/stop
- Emergency stop
- Failed to reach loading voltage/frequency
- Charge fail
- Low DC Voltage
 - CAN diagnostics and CAN fail/error

: +971 6 741 0802, M +971 5 2641 4219

PO BOX: 3794, Ajman, UAE

STANDARD SPECIFICATIONS

80 KVA

3 PHASE

50Hz

1. ENGINE

Perkins four stroke heavy duty high performance industrial type diesel engine.

2. ENGINE FILTRATION SYSTEM

- · Cartridge type dry air filter.
- Two cartridge type fuel filter.
- Full flow lube oil filter.
 All filters have replaceable elements.

3. COOLING RADIATOR

Radiator and cooling fan, complete with safety guards designed to cool the engine at high ambient temperatures (consult your dealer for de-ration factors)

4. EXHAUST SYSTEM

Exhaust gas flow Maximum allowable back pressure 31..3 (m3/min) 18.0 (kPa)

5. CIRCUIT BREAKER TYPE

3 pole MCCB. (4 pole is optional)

6. FUEL SYSTEM

The baseframe design is incorporated with an integral fuel tank with a capacity of approx.. 8 hours running at Full load. The tank is supplied complete with fill cap breather, fuel feed and return lines to the Engine and the drain plug.

7. ALTERNATOR

7.1 INSULATION SYSTEM

- . The insulation system is Class H.
- All windings are impregnated in either a triple dip thermoset-Ting liquid, oil and acid resisting polyester varnish or vacuum pressure impregnated with a special polyester resin
- Heavy coat of antitracking varnish additional protection Against moisture or condensation.

7.2 AUTOMATIC VOLTAGE REGULATOR (AVR)

The fully sealed Automatic Voltage Regulator maintains

The Voltage Regulation at ±1%. Nominal adjustment by means of a trim pot incorporated on the AVR.

8. MOUNTING ARRANGEMENT

8.1 COUPLING

The Engine and Alternator are directly coupled by means of an SAE flange. The Engine flywheel is flexibly coupled to the Alternator rotor.

8.2 ANTI-VIBRATION MOUNTING PADS

Anti-Vibration pads are affixed between tge Engine/Alternator feet and the Baseframe thus ensuring complete vibration isolation of the rotating assembly.

8.3 SAFETY GUARDS

The Fan & Fan Drive along with the battery Charging Alternator are Safety Guard protected for personnel protection.

60Hz

92 KVA

3 PHASE

9. FACTORY TEST

- The Generating set is load tested before dispatch
- All protective devise control functions and site load conditions are simulated. The generator and its systems are checked before dispatch.

10. EQUIPMENT FINISHING

All mild steel components are fully degreased and painted with powder coated paint to ensure maximum scuff resistance and durability.

11. DOCUMENTATION

Operation & Maintenance manual, Circuit wiring diagrams and Commissioning/ Fault Finding instruction leaflets are accompanied with the Generator.

12. QUALITY STANDARDS

The equipment meets the following standards, BS4999, BS5000, BS5514 IEC 60034, VDE0530, NEMA MG 1.22 and ISO 8528.


13. WARRANTY


All of the Generating sets are covered under a warranty policy For a period of 12 months or 1000 working hours. Warranty of the equipment is in line with manufacturers warranty terms & conditions. (check warranty statement for more details, as it may vary for different countries.)


In line with the continuous product development, we reserve The right to change specifications without notice.


STANDARD GENERATOR DIMENSION AND WEIGHT

Silent Type (with Soundproof Canopy)











Open Type (without Soundproof Canopy)





Tel : +971 6 741 0802, M +971 5 2641 4219 Fax : +971 6 740 8056 PO BOX: 3794, Ajman, UAE

E-mail: info@jimenpower.com Web: www.jimenpower.com